

RESOLUTION NO. 87-42

AWARD - POLEMOUNT TRANSFORMERS

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened by the City Clerk of this City on March 17, 1987 at 11:00 a.m. for the contract for Polemount Transformers, described in the specifications therefor approved by the City Council February 18, 1987; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as follows:

<u>Bidder</u>	<u>Amount</u>
General Electric Supply	\$31,286.00
Wesco	\$30,590.40
RTE	\$32,797.46
Western States Electric	\$37,426.48

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Exhibit "A" attached hereto and thereby made a part hereof.

WHEREAS, the City Manager recommends that award be made to:

RTE Corporation

7 - 37 1/2 KVA single-phase 240/120	\$ 6,767.04
5 - 50 KVA single-phase 240/120	5,225.80
1 - 112 1/2 KVA three-phase 208Y/120	3,446.06
2 - 225 KVA three-phase 208Y/120	9,109.64
2 - 150 KVA three-phase 408Y/277	7,133.80
1 - 300 KVA three-phase 480Y/277	5,023.34
	<u>\$36,705.68</u>

Maydwell & Hartzell, Inc.

5 - 75 KVA single-phase 240/120	\$ 6,704.50
3 - 100 KVA single-phase 240/120	4,919.46
1 - 750 KVA three-phase 480Y/277	10,461.14
1 - 1000 KVA three-phase 480Y/277	11,654.70
	<u>\$33,739.80</u>

General Electric Supply Co.

1 - 1500 KVA three-phase 4160Y/2400 \$15,187.68


Dated: April 1, 1987

I hereby certify that Resolution No. 87-43
was passed and adopted by the City Council
of the City of Lodi in a regular meeting
held April 1, 1987 by the following vote:

Ayes: Council Members - Hinchman, Pinkerton,
Snider, Olson, and
Reid (Mayor)

Noes: Council Members - None

Absent: Council Members - None


Alice M. Reimche
City Clerk

 * City of Lodi *
 • Utility Department *
 * Transformer Bid Evaluation *

EUD-87-3

DATE: 03-17-87

TYPE: C.P., single-phase, overhead pole-bolted 12,000-volt primary, 120/240-secondary

SIZE: 50 KVA

QTY: 10

SUPPLIER	ADDRESS	"A" TOTAL PRICE FOB LODI INCL TAX (\$)	"B" COST OF LOSSES (\$)	"A + B" LIFE-CYCLE COST (\$)	DELIVERY (WEEKS)
WESCO	Concord, CA	8,130.20	7,365.00	15,495.20	9
RTE CORP.	Tigard, OR	8,639.00	7,147.00	15,786.00	13
GENERAL ELECTRIC CO.	Emeryville, CA	8,352.80	7,510.50	15,863.30	11-13
WESTERN STATES ELECTRIC	Portland, OR	10,017.00	6,858.00	16,875.00	16

DATE: 03-17-87

TYPE: C.P., single-phase, overhead pole-bolted 12,000-volt primary, 120/240-secondary

SIZE: 75 KVA

QTY: 10

SUPPLIER	ADDRESS	"A" TOTAL PRICE FOB LODI INCL TAX (\$)	"B" COST OF LOSSES (\$)	"A + B" LIFE-CYCLE COST (\$)	DELIVERY (WEEKS)
GENERAL ELECTRIC CO.	Emeryville, CA	12,645.80	9,867.50	22,513.30	11-13
WESCO	Concord, CA	12,105.20	10,486.00	22,591.20	9
RTE CORP.	Tigard, OR	12,932.00	10,955.00	23,887.00	13
WESTERN STATES ELECTRIC	Portland, OR	15,645.60	10,921.00	26,566.60	16

DATE: 03-17-87

TYPE: C.P., single-phase, overhead pole-bolted 12,000-volt primary, 120/240-secondary

SIZE: 100 KVA

QTY: 1

SUPPLIER	ADDRESS	"A" TOTAL PRICE FOB LODI INCL TAX (\$)	"B" COST OF LOSSES (\$)	"A + B" LIFE-CYCLE COST (\$)	DELIVERY (WEEKS)
GENERAL ELECTRIC CO.	Emeryville, CA	1,507.32	1,274.45	2,781.77	11-13
WESCO	Concord, CA	1,463.86	1,324.95	2,788.81	9
RTE CORP.	Tigard, OR	1,939.80	1,209.10	3,148.90	14
WESTERN STATES ELECTRIC	Portland, OR	1,927.08	1,334.85	3,261.93	16

*** *****
 * City of Lodi *
 • Utility Department *
 * Transformer Bid Evaluation *

EUD-87-3

DATE: 03-17-87

TYPE: Conventional, single-phase, overhead pole-bolted 12,000-volt primary, 120/240-secondary

SIZE: 25 KVA

QTY: 1

SUPPLIER	ADDRESS	"A" TOTAL PRICE FOB LODI INCL TAX (\$)	"B" COST OF LOSSES (\$)	"A + B" LIFE-CYCLE COST (\$)	DELIVERY (WEEKS)
WESCO	Concord, CA	501.38	429.85	931.23	9
GENERAL ELECTRIC CO.	Emeryville, CA	578.76	375.40	954.16	11-13
RTE CORP.	Tigard, OR	563.92	429.40	993.32	12
WESTERN STATES ELECTRIC	Portland, OR	657.20	389.65	1,046.85	1

DATE: 03-17-87

TYPE: Conventional, single-phase, overhead pole-bolted 12,000-volt primary, 120/240-secondary

SIZE: 37.5 KVA

QTY: 4

SUPPLIER	ADDRESS	"A" TOTAL PRICE FOB LODI INCL TAX (\$)	"B" COST OF LOSSES (\$)	"A + B" LIFE-CYCLE COST (\$)	DELIVERY (WEEKS)
GENERAL ELECTRIC CO.	Emeryville, CA	2,607.60	2,227.20	4,834.80	11-13
RTE CORP.	Tigard, OR	2,739.04	2,138.80	4,877.84	13
WESCO	Concord, CA	2,726.32	2,258.20	4,984.52	9
WESTERN STATES ELECTRIC	Portland, OR	3,243.60	2,183.40	5,427.00	IN STOCK

DATE: 03-17-87

TYPE: Conventional, single-phase, overhead pole-bolted 12,000-volt primary, 120/240-secondary

SIZE: 75 KVA

QTY: 5

SUPPLIER	ADDRESS	"A" TOTAL PRICE FOB LODI INCL TAX (\$)	"B" COST OF LOSSES (\$)	"A + B" LIFE-CYCLE COST (\$)	DELIVERY (WEEKS)
GENERAL ELECTRIC CO.	Emeryville, CA	5,591.50	4,820.00	10,411.50	11-13
WESTERN STATES ELECTRIC	Portland, OR	5,936.00	4,771.00	10,707.00	16
WESCO	Concord, CA	5,692.20	5,028.50	10,720.70	9
RTE CORP.	Tigard, OR	5,983.70	5,447.50	11,431.20	14